

TOWN OF SMITHS FALLS



SMITHS FALLS DRINKING WATER SYSTEM 2023 ANNUAL REPORT

Smiths Falls Drinking Water System

2023 Annual Report

| | |
|--|---|
| Drinking-Water System Number: | 220001307 |
| Drinking-Water System Name: | Smiths Falls Drinking Water System |
| Drinking-Water System Owner: | Corporation of the Town of Smiths Falls |
| Drinking-Water System Category: | Large Municipal Drinking Water System |
| Period being reported: | January 1 st to December 31 st , 2023 |

Complete if your Category is Large Municipal Residential or Small Municipal Residential

Does your Drinking-Water System serve more than 10,000 people?

Yes ☐ No ☒

Is your annual report available to the public at no charge on a web site on the Internet?

Yes ☒ No ☐

Location where Annual Report required under O. Reg. 170/03 Schedule 11 will be available to the public.

www.smithsfalls.ca

Smiths Falls Town Hall Complex
77 Beckwith St. N
Smiths Falls, ON K7A 4T6

Complete for all other Categories.

Number of Designated Facilities served:
N/A

Did you provide a copy of your annual report to all Designated Facilities you serve? N/A

Number of Interested Authorities you report to: N/A

Did you provide a copy of your annual report to all Interested Authorities you report to for each Designated Facility?
N/A

List all Drinking-Water Systems (if any), which receive all of their drinking water from your system:

| Drinking Water System Name | Drinking Water System Number |
|--|-------------------------------------|
| Atironto Subdivision – Montague Township | 260006828 |

Did you provide a copy of your annual report to all Drinking-Water System owners that are connected to you and to whom you provide all of its drinking water?

Yes ☒ No ☐

Indicate how you notified system users that your annual report is available, and is free of charge.

☒ Public access/notice via the web

☐ Public access/notice via a newspaper

Smiths Falls Drinking Water System

2023 Annual Report

Describe your Drinking-Water System

The Smiths Falls Drinking Water System is comprised of the Water Treatment Plant (WTP) and Distribution system (WDS) which together provides a supply of potable water to the residents and businesses of the Town of Smiths Falls.

The WTP is a Class IV high-rate dissolved air floatation (AquaDAF ®) surface water plant having an approved design capacity of 14,000 m³/d with a future expansion to 18,000 m³/d. Raw water for the treatment process is drawn from the Rideau River (surface water). The intake structure is located upstream of the WTP approximately 170m. The intake consists of a concrete structure and a 762-millimeter diameter concrete pipe connecting the intake to the diversion chamber where the raw water is directed into the WTP.

Low lift pumps supply water to the AquaDAF ® which is a high-rate dissolved air floatation clarifier. A coagulant & polymer are mixed with the Raw Water to aid in particle removal. Dissolved air will float these particles to form a blanket of sludge which is discharged to the wastewater collection system.

Clarified water flows to 3 granular activate carbon (GAC) & sand filters where further particle removal will take place.

Processes involved include: UV disinfection; chlorination with chlorine gas; corrosion control; fluoridation; residue management and de-chlorination.

The WDS is a Class I subsystem, consisting of 61.94 kilometers (km) of mains, 1096 valves, 332 hydrants and 3010 house services. With a 49.2 meter (m) high water tower that contains 945.75 cubic meters (m³) of storage.

List all water treatment chemicals used over this reporting period

| CHEMICAL NAME | USE | SUPPLIER |
|---------------------|-------------------------------|--------------------|
| PAX-XL6 | Coagulant | Kemira |
| Magnafloc LT22s | Polymer | Northland Chemical |
| Chlorine Gas | Disinfection | Brenntag |
| Sodium Hydroxide | Corrosion Control | Brenntag |
| Fluorosilicic Acid | Fluoride | PVS Benson |
| Calcium Thiosulfate | De-chlorination | Cleartech |
| Sodium Chlorite | Pre-treatment Zebra Mussel | PVS Benson |

Were any significant expenses incurred to?

- ☒ Install required equipment
- ☒ Repair required equipment
- ☐ Replace required equipment

Smiths Falls Drinking Water System

2023 Annual Report

Please provide a brief description and a breakdown of monetary expenses incurred

- GAC Replacement – \$385,507
- High lift pump rebuild - \$13,006
- Low lift pump rebuild - \$7,017
- New Tower detailed design/Site clearing - \$152,700
- WD Valve Maintenance trailer - \$126,651
- Catherine Street reconstruction - \$1,145,399
- Zebre Mussell/THMM reduction - \$96,060
- AquaDAF 1&2 Actuators - \$20,723
- Water meters - \$59,315
- Old Water Tower Communications - \$11,521
- Water Plant Exterior doors - \$58,308

Provide details on the notices submitted in accordance with subsection 18(1) of the Safe Drinking Water Act or section 16-4 of Schedule 16 of O.Reg.170/03 and reported to Spills Action Centre

| Incident Date | Parameter | Result | Unit of Measure | Corrective Action | Corrective Action Date |
|-------------------------------------|---------------------|--------|-----------------------------------|--|---|
| AWQI 161776 (2023-Apr-18) | Total Coliform (TC) | 1 | 1 colony forming unit (CFU)/100mL | TC present at the Union St flusher. Re-samples collected 2023-Apr-18 from Union St flusher, FAC was 0.60mg/L, downstream sample collected at hydrant (Book Binding) FAC was 1.53 mg/L, no upstream sample. Verbal received on 2023-Apr-20 that samples zero for TC and E. Coli | 2023-Apr-18 Section 2B submitted 2023-Apr-24 |
| Incident #1-3JETDQ (2023-Jun-13) | Tower overflow | N/A | N/A | Tower briefly overflowed due to issues with instrumentation and SCADA. Issue resolved by looking into program | 2023-Jun-13 |

Microbiological testing completed under Schedule 10, 11 or 12 of Regulation 170/03 during this reporting period.

| | Number of Samples | Range of E. coli Results (min #) - (max #) (CFU/100mL) | Range of Total Coliform Results (min #) - (max #) (CFU/100mL) | Number of HPC Samples | Range of HPC Results (min #) - (max #) (CFU/100mL) |
|---|-------------------|--|---|-----------------------|--|
| Raw | 53 | 0 - 101 | 10 - 500 | N/A | N/A |
| Treated | 52 | 0 - 0 | 0 - 0 | 52 | 10 - 300 |
| <u>Distribution</u> - Routine | 311 | 0 - 0 | 0 - 1 * | 311 | <10 - 150 |
| <u>Distribution</u> Water main Repairs/new installations/service repairs | 61 | 0 - 0 | 0 - 1 ** | 58 | <10 - 300 |

*AWQI 161776 see above table for more information

** Non-regulatory sample Catherine St. capital project

Smiths Falls Drinking Water System

2023 Annual Report

Operational testing completed under Schedule 7, 8 or 9 of Regulation 170/03 during the period covered by this Annual Report.

| Parameter Tested - (Online Analyzers) | Number of Grab Samples | Range of Results | | |
|---|--|------------------|---------|---------|
| | | Minimum | Average | Maximum |
| Turbidity - Raw Water (NTU) AIT 102 | Continuous Monitoring ¹ | 0.000 | 0.806 | 49.992 |
| Turbidity - Raw Water (NTU) | (365 bench test) | 0.297 | 0.103 | 3.86 |
| Turbidity - Filter #1 (NTU) AIT 111 | Continuous Monitoring ² | 0.000 | 0.033 | 5.00 |
| Turbidity - Filter #1 (NTU) | (51 bench test) | 0.047 | 0.103 | 0.178 |
| Turbidity - Filter #2 (NTU) AIT 121 | Continuous Monitoring ² | 0.000 | 0.035 | 5.00 |
| Turbidity - Filter #2 (NTU) | (52 bench test) | 0.045 | 0.113 | 0.217 |
| Turbidity - Filter #3 (NTU) AIT 131 | Continuous Monitoring ² | 0.000 | 0.033 | 5.00 |
| Turbidity - Filter #3 (NTU) | (51 bench test) | 0.033 | 0.128 | 0.365 |
| Turbidity - Finished Water (NTU) AIT 184 | Continuous Monitoring ³ | 0.000 | 0.046 | 5.000 |
| Turbidity - Finished Water (NTU) | (248 bench test) | 0.030 | 0.091 | 0.363 |
| | | | | |
| Chlorine Total - Zebra Mussel (operation May to October mg/L) AIT 103 | Continuous Monitoring ⁷ Total Chlorine | N/A | N/A | N/A |
| Chlorine Total - Zebra Mussel (operation May to October mg/L) | (0 bench test) ⁸ | N/A | N/A | N/A |
| Chlorine Free - Pre-Reservoir (mg/L) AIT 165 | Continuous Monitoring ⁵ Free Chlorine | 0.00 | 2.29 | 5.00 |
| Chlorine Free - Pre-Reservoir (mg/L) | (52 bench test) | 1.24 | 2.04 | 2.74 |
| Chlorine Free - Post Reservoir (mg/L) AIT 180 | Continuous Monitoring ⁵ Free Chlorine | 0.00 | 1.78 | 3.02 |
| Chlorine Free - Post Reservoir (mg/L) | (52 bench test) | 1.07 | 1.61 | 2.23 |
| Chlorine Free - Finished Water (mg/L) AIT 185 | Continuous Monitoring ⁵ Free Chlorine | 0.00 | 1.75 | 2.35 |
| Chlorine Free - Finished Water (mg/L) | (249 bench test) | 1.12 | 1.68 | 2.13 |
| Chlorine Total - Finished Water (mg/L) AIT 186 | Continuous Monitoring ⁶ Total Chlorine | 0.00 | 1.99 | 2.63 |
| Chlorine Total - Finished Water (mg/L) | (249 bench test) | 1.40 | 1.90 | 2.49 |
| | | | | |
| Fluoride - Finished Water (mg/L) AIT 187 | Continuous Monitoring ⁴ | 0.00 | 0.62 | 2.00 |
| Fluoride - Finished Water (mg/L) | (365 bench test) | 0.24 | 0.57 | 1.15 |
| | | | | |
| UV Transmittance (%) AIT 160 | Continuous Monitoring ⁹ | 70.0 | 96.6 | 100.0 |
| UV Transmittance (%) | (246 bench test) | 80.8 | 92.8 | 101.4 |

Notes for above table operational testing completed under Schedule 7, 8 or 9:

1. High raw water turbidity spikes occur when the low lift pumps (LLP) start and stop, maintenance, calibration and flushing of lines.
2. High filter turbidity results of filter backwash, process upset or calibration.
3. High finished water turbidity results of high lift pumps (HLP) starting or calibration.
4. High fluoride readings occur on HLP starts, maintenance or calibration while chemical system was off.
5. Low free chlorine residual (pre-reservoir, post reservoir and finished water) result of generator backup power testing, maintenance, or calibration.
6. Low total chlorine residual (finished water) result of generator backup power testing, maintenance, or calibration.

Smiths Falls Drinking Water System 2023 Annual Report

7. High total chlorine residuals (for zebra mussel control) can be due the sampling alternates between intake and LLP header.
8. Bench tests for total chlorine (zebra mussel) are sampled from the raw water stainless steel sample tap located in pump gallery or raw water sample tap in lab.
9. Low UV transmittance result of generator backup power testing, maintenance, calibration or Optiview failure.

Summary of additional testing and sampling carried out in accordance with the requirement of an approval, order or other legal instrument.

| Date of legal instrument issued | Parameter | Date Sampled (YYYY-MM-DD) | Result (µg/L) | Quarterly Average (µg/L) | Rolling Annual Average Quarter (µg/L) |
|--|-----------|---------------------------|---------------|--------------------------|---------------------------------------|
| Municipal Drinking Water License #164-101 Issue #6 2021-Jun-06 | TTHM | 2023-Jan-03 | 58.0 | 51.7 | 74.0 |
| | | 2023-Feb-06 | 47.0 | | |
| | | 2023-Mar-06 | 50.0 | | |
| | | 2023-Apr-03 | 63.0 | 32.0 | 63.2 |
| | | 2023-May-01 | 7.0 | | |
| | | 2023-Jun-05 | 26.0 | | |
| | | 2023-Jul-04 | 41.0 | 53.3 | 51.4 |
| | | 2023-Aug-08 | 45.0 | | |
| | | 2023-Sept-05 | 74.0 | | |
| | | 2023-Oct-02 | 52.0 | 41.0 | 44.5 |
| | | 2023-Nov-06 | 32.0 | | |
| | | 2023-Dec-04 | 39.0 | | |

Notes:

1. Maximum Allowable Concentration (MAC) for THM is based on a four-quarter rolling annual average of 0.100 mg/L or 100.0 ug/L
2. Granular activated carbon (GAC) changed out in all three filters beginning of April

Summary of additional testing and sampling carried out in accordance with the requirement of an approval, order or other legal instrument.

| Date of legal instrument issued | Parameter | Date Sampled (YYYY-MM-DD) | Result –Monthly TSS Average (mg/L) | Result –Monthly Grab Average Total Chlorine (mg/L) |
|---|-------------------|---------------------------|------------------------------------|--|
| Municipal Drinking Water License #164-101 issue #6 (Schedule C section 1.5 table 3) | TSS (grab sample) | 2023-Jan-10 | 9.30 | 0.01 |
| | | 2023-Feb-14 | 3.40 | 0.02 |
| | | 2023-Mar-09 | 8.07 | 0.00 |
| | | 2023-Apr-21 | 3.93 | 0.02 |
| | | 2023-May-15 | 6.07 | 0.01 |
| | | 2023-Jun-08 | 3.47 | 0.01 |
| | | 2023-Jul-10 | 1.73 | 0.01 |
| | | 2023-Aug-14 | 7.23 | 0.02 |
| | | 2023-Sept-15 | 2.17 | 0.02 |
| | | 2023-Oct-13 | 4.87 | 0.02 |
| | | 2023-Nov-10 | 4.60 | 0.01 |
| | | 2023-Dec-20 | 4.20 | 0.04 |
| | | Annual average | 4.92 | 0.02 |

Summary of Inorganic parameters tested during this reporting period or the most recent sample results

| Parameter | Sample Date (YYYY-MM-DD) | Result Value | Unit of Measure | Exceedance |
|-----------|--------------------------|--------------|-----------------|------------|
| Antimony | 2023-Apr-03 | <0.6 | µg/L | No |
| Arsenic | 2023-Apr-03 | <0.2 | µg/L | No |
| Barium | 2023-Apr-03 | 38.4 | µg/L | No |
| Boron | 2023-Apr-03 | 12 | µg/L | No |
| Cadmium | 2023-Apr-03 | 0.003 | µg/L | No |

Smiths Falls Drinking Water System 2023 Annual Report

| | | | | |
|---------------------------------|-------------|-------|------|----|
| Chromium | 2023-Apr-03 | 0.31 | µg/L | No |
| Mercury | 2023-Apr-03 | <0.01 | µg/L | No |
| Selenium | 2023-Apr-03 | 0.05 | µg/L | No |
| Uranium | 2023-Apr-03 | 0.021 | µg/L | No |
| 1 st Quarter Nitrite | 2023-Feb-06 | <0.05 | mg/L | No |
| 2 nd Quarter Nitrite | 2023-May-01 | <0.05 | mg/L | No |
| 3 rd Quarter Nitrite | 2023-Aug-08 | <0.05 | mg/L | No |
| 4 th Quarter Nitrite | 2023-Nov-06 | 0.05 | mg/L | No |
| 1 st Quarter Nitrate | 2023-Feb-06 | 0.18 | mg/L | No |
| 2 nd Quarter Nitrate | 2023-May-01 | <0.05 | mg/L | No |
| 3 rd Quarter Nitrate | 2023-Aug-08 | <0.05 | mg/L | No |
| 4 th Quarter Nitrate | 2023-Nov-06 | 0.05 | mg/L | No |
| Sodium | 2023-Apr-03 | 13.8 | mg/L | No |

| Parameter | Sample Date (YYYY-MM-DD) | Result Value (ug/L) | Rolling Annual Average Quarter (ug/L) | Exceedance |
|------------------------------|-----------------------------|------------------------|--|------------|
| HAA5 1 st Quarter | 2023-Feb-06 | 32.1 | 49.4 | No |
| HAA5 2 nd Quarter | 2023-May-01 | 5.3 | 35.9 | No |
| HAA5 3 rd Quarter | 2023-Aug-08 | 36.9 | 31.1 | No |
| HAA5 4 th Quarter | 2023-Nov-06 | 30.7 | 26.3 | No |

Notes:

- Maximum Allowable Concentration (MAC) for HAA is based on a four-quarter rolling annual average of 0.080 mg/L or 80.0 ug/L
- Granular activated carbon (GAC) changed out in all three filters beginning of April

Summary of lead testing under Schedule 15.1 during this reporting period & MDWL #164-101 Issue #6 Schedule C, Section 6.6

| Location Type | Number of Total Samples | Range of Lead Results 1 st One Litre Sample min# - max # (mg/L) | Number of Exceedances 1 st Sample | Range of Lead Results 2 nd One Litre Sample min# - max # (mg/L) | Number of Exceedances 2 nd Sample |
|----------------------------|-------------------------|---|---|---|---|
| Plumbing – residential | 23 | 0.000080 – 0.059700 | 6 | 0.000050 – 0.063000 | 6 |
| Plumbing – non residential | 0 | N/A | N/A | N/A | N/A |
| Distribution | 4 | 0.000030 – 0.000960 | 0 | N/A | N/A |
| Finished Water | 4 | 0.000020 – 0.000020 | 0 | N/A | N/A |

| Location Type | Number of Total samples | pH (min # - max #) | Number of Total samples | Temperature °C (min # - max #) |
|----------------------------|-------------------------|-----------------------|-------------------------|-----------------------------------|
| Plumbing – residential | 23 | 7.12 – 7.83 | 23 | 6.7 – 22.1 |
| Plumbing – non residential | 0 | N/A | N/A | N/A |
| Distribution | 4 | 7.53 – 7.80 | 4 | 4.8 – 21.6 |
| Finished Water | 4 | 7.40 – 7.70 | 4 | 7.5 – 22.9 |

Smiths Falls Drinking Water System

2023 Annual Report

| Location Type | Number of Total samples | Alkalinity mg/L (min # - max #) |
|----------------------------|-------------------------|---------------------------------|
| Plumbing – residential | 23 | 72 – 105 |
| Plumbing – non-residential | 0 | N/A |
| Distribution | 4 | 73 – 78 |
| Finished Water | 4 | 77 – 97 |

Notes:

1. Maximum Allowable Concentration (MAC) for lead is 0.010 mg/L or 10.0 ug/L.
2. Only Distribution lead samples above 0.010 mg/L or 10.0 ug/L are reportable.
3. Plumbing samples from residential or non-residential, the occupant receives a letter to indicate if a sample is above the MAC, the results and an information sheet on lead.

Summary of Organic parameters sampled during this reporting period or the most recent sample results

| Parameter | Sample Date (YYYY-MM-DD) | Result Value | Unit of Measure | Exceedance |
|--|--------------------------|--------------|-----------------|------------|
| Alachlor | 2023-Apr-03 | <0.02 | µg/L | No |
| Atrazine | 2023-Apr-03 | <0.01 | µg/L | No |
| Atrazine + N-dealkylated metabolites | 2023-Apr-03 | <0.01 | µg/L | No |
| Azinphos-methyl | 2023-Apr-03 | <0.05 | µg/L | No |
| Benzene | 2023-Apr-03 | <0.32 | µg/L | No |
| Benzo(a)pyrene | 2023-Apr-03 | <0.004 | µg/L | No |
| Bromoxynil | 2023-Apr-03 | <0.33 | µg/L | No |
| Carbaryl | 2023-Apr-03 | <0.05 | µg/L | No |
| Carbofuran | 2023-Apr-03 | <0.01 | µg/L | No |
| Carbon Tetrachloride | 2023-Apr-03 | <0.17 | µg/L | No |
| Chlorpyrifos | 2023-Apr-03 | <0.02 | µg/L | No |
| Desethyl atrazine | 2023-Apr-03 | <0.01 | µg/L | No |
| Diazinon | 2023-Apr-03 | <0.02 | µg/L | No |
| Dicamba | 2023-Apr-03 | <0.20 | µg/L | No |
| 1,2-Dichlorobenzene | 2023-Apr-03 | <0.41 | µg/L | No |
| 1,4-Dichlorobenzene | 2023-Apr-03 | <0.36 | µg/L | No |
| 1,1-Dichloroethylene (vinylidene chloride) | 2023-Apr-03 | <0.33 | µg/L | No |
| 1,2-Dichloroethane | 2023-Apr-03 | <0.35 | µg/L | No |
| Dichloromethane | 2023-Apr-03 | <0.35 | µg/L | No |
| 2,4-Dichlorophenol | 2023-Apr-03 | <0.15 | µg/L | No |
| 2,4-Dichlorophenoxy acetic acid (2,4-D) | 2023-Apr-03 | <0.19 | µg/L | No |
| Diclofop-methyl | 2023-Apr-03 | <0.40 | µg/L | No |
| Dimethoate | 2023-Apr-03 | <0.06 | µg/L | No |
| Diquat | 2023-Apr-03 | <1 | µg/L | No |
| Diuron | 2023-Apr-03 | <0.03 | µg/L | No |
| Glyphosate | 2023-Apr-03 | <1 | µg/L | No |
| Malathion | 2023-Apr-03 | <0.02 | µg/L | No |
| 2-Methyl-4-chlorophenoxyacetic acid (MCPA) | 2023-Apr-03 | <0.00012 | µg/L | No |

Smiths Falls Drinking Water System 2023 Annual Report

| | | | | |
|---|-------------|-------|------|----|
| Metolachlor | 2023-Apr-03 | <0.01 | µg/L | No |
| Metribuzin | 2023-Apr-03 | <0.02 | µg/L | No |
| Monochlorobenzene | 2023-Apr-03 | <0.3 | µg/L | No |
| Paraquat | 2023-Apr-03 | <1 | µg/L | No |
| Pentachlorophenol | 2023-Apr-03 | <0.15 | µg/L | No |
| Phorate | 2023-Apr-03 | <0.01 | µg/L | No |
| Picloram | 2023-Apr-03 | <1 | µg/L | No |
| Polychlorinated Biphenyls (PCB) | 2023-Apr-03 | <0.04 | µg/L | No |
| Prometryne | 2023-Apr-03 | <0.03 | µg/L | No |
| Simazine | 2023-Apr-03 | <0.01 | µg/L | No |
| Terbufos | 2023-Apr-03 | <0.01 | µg/L | No |
| Tetrachloroethylene (perchloroethylene) | 2023-Apr-03 | <0.35 | µg/L | No |
| 2,3,4,6-Tetrachlorophenol | 2023-Apr-03 | <0.20 | µg/L | No |
| Triallate | 2023-Apr-03 | <0.01 | µg/L | No |
| Trichloroethylene | 2023-Apr-03 | <0.44 | µg/L | No |
| 2,4,6-Trichlorophenol | 2023-Apr-03 | <0.25 | µg/L | No |
| Trifluralin | 2023-Apr-03 | <0.02 | µg/L | No |
| Vinyl Chloride | 2023-Apr-03 | <0.17 | µg/L | No |

List any Inorganic or Organic parameter(s) that exceeded half the standard prescribed in Schedule 2 of Ontario Drinking Water Quality Standards.

| Parameter | Result Value | Unit of Measure | Date of Sample |
|-----------|--------------|-----------------|----------------|
| | | | |
| | | | |

Glossary

AWQI = adverse water quality indicator
 CFU = colony forming units
 DWS = drinking water system
 DS = distribution system
 EA = Environmental Assessment
 HAA5 = total haloacetic acid
 mg/L = milligrams per liter
 MDWL = Municipal Drinking Water License
 TTHM = trihalomethane
 ug/L = micrograms per liter
 WTP = water treatment plant

Contact for more information:

Sarah E. Cooke
 Water & Wastewater Compliance Coordinator
 Phone: 613-283-4124 ext. 5502
 Email: scooke@smithsfalls.ca

Jason Barlow
 Manager Water & Wastewater
 Phone: 613-283-4124 ext. 5501
 Email: jbarlow@smithsfalls.ca